



Life Science Laboratories, Inc.

Date Printed: 4/15/21

Laboratory Analysis Report Prepared For Ithaca City School District

Client Project ID: ICSD-Fall Creek Elem. School - Lead Study

LSL Project ID: 2104722

Paul Alexander
Ithaca City School District
602 Hancock St.
Ithaca, NY 14850 USA

Phone: (607) 274-2142

Authorization: FN-00605

A copy of this report was sent to:

TST BOCES; Tompkins Co. DOH

Sample ID: FCE-002-F

LSL Sample ID: 2104722-001

Location:

Receive Date/Time: 04/06/21 16:30

Sampled: 04/02/21 3:53

Project Rec'd by: tjn1

Sampled By: MA

Matrix: PWS

Analytical Method	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
Analyte	Result Units			
(1) Lead Study				
Number of Samples	20			MT

Please refer to the chain of custody form on the last page of this report for the detailed descriptions of where these samples were taken.

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain data qualifiers and specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab
5854 Butternut Drive
East Syracuse, NY 13057
Tel. (315) 445-1900
Fax (315) 445-1104
NYS DOH ELAP #10248

LSL North Lab
131 St. Lawrence Avenue
Waddington, NY 13694
Tel. (315) 388-4476
Fax (315) 388-4061
NYS DOH ELAP #10900

LSL Finger Lakes Lab
16 N. Main St., PO Box 424
Wayland, NY 14572
Tel. (585) 213-4090
Fax (585) 213-4192
NYS DOH ELAP #11667

LSL Southern Tier Office
Cuba, NY
Tel. (585) 209-4032

LSL MidLakes Office
Canandaigua, NY
Tel. (585) 728-3320

Reviewed by:

Kristin E. Carpenter, Quality Staff

Date:

04/19/21

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-002-F*
Lab ID: 2104722-001A
Collection Date: 04/02/21 3:53
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0026	mg/L	04/13/21 15:37

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-010-BF*
Lab ID: 2104722-002A
Collection Date: 04/02/21 3:53
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 15:41

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-012-F*
Lab ID: 2104722-003A
Collection Date: 04/02/21 3:55
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 15:44

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: FCE-013-F

Lab ID: 2104722-004A

Collection Date: 04/02/21 3:55

Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 15:47

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-015-F*
Lab ID: 2104722-005A
Collection Date: 04/02/21 3:58
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 15:51

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: FCE-017-F

Lab ID: 2104722-006A

Collection Date: 04/02/21 3:57

Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 15:54

Qualifiers:

- * Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: FCE-019-F

Lab ID: 2104722-007A
Collection Date: 04/02/21 3:59
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 15:58

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-022-F*
Lab ID: 2104722-008A
Collection Date: 04/02/21 3:59
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 16:01

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-025-BF*

Lab ID: 2104722-009A
Collection Date: 04/02/21 3:57
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 16:04

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-031-F*
Lab ID: 2104722-010A
Collection Date: 04/02/21 4:00
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 16:14

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-033-F*
Lab ID: 2104722-011A
Collection Date: 04/02/21 4:00
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 16:18

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL.)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-037-F*
Lab ID: 2104722-012A
Collection Date: 04/02/21 4:10
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 16:21

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-039-F*
Lab ID: 2104722-013A
Collection Date: 04/02/21 4:10
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 16:24

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-041-F*

Lab ID: 2104722-014A
Collection Date: 04/02/21 4:09
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 16:28

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-043-F*
Lab ID: 2104722-015A
Collection Date: 04/02/21 4:07
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 16:31

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-045-F*
Lab ID: 2104722-016A
Collection Date: 04/02/21 4:09
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	0.0010	mg/L	04/13/21 16:35

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - HI Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-047-F*
Lab ID: 2104722-017A
Collection Date: 04/02/21 4:08
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8, Rev. 5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 16:38

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-049-F*
Lab ID: 2104722-018A
Collection Date: 04/02/21 4:06
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 13:04

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-061-BF*
Lab ID: 2104722-019A
Collection Date: 04/02/21 4:03
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	< 0.0010	mg/L	04/13/21 13:21

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results


State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Fall Creek Elem. School - Lead Study
Matrix: PWS

Client Sample ID: *FCE-063-F*
Lab ID: 2104722-020A
Collection Date: 04/02/21 4:03
Date Received: 04/06/21 16:30

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0010	mg/L	04/13/21 13:24

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits



Client: Ithaca City School District **Phone #** (607) 280-3900 **Telefax #** (315) 445-1104
Address: 400 Lake Street **Fax #**
 Ithaca, NY 14850

Contact Person: Paul Alexander **LSL Project #:**
Client's Site I.D.: ICSD - Fall Creek Elementary School - Lead

LSL Sample Number	Client's Sample Identifications	Authorization / to #:		Sample Date	Sample Time	Type	Matrix	Preserv. Added	#	size/type	CONTAINER ANALYSES	Free Cl (mg/L)	Pres. Check
		grab	comp.										
001A	FCE-002-F	X		4/2/2021	3:53AM	X	PW	NONE	1	8 oz	FCE 1 Lead by EPA 200.8		< 2
2	FCE-010-BF	X		4/2/2021	3:53AM	X	PW	NONE	1	8 oz	2 Lead by EPA 200.8		
3	FCE-012-F	X		4/2/2021	3:55AM	X	PW	NONE	1	8 oz	3 Lead by EPA 200.8		
4	FCE-013-F	X		4/2/2021	3:55AM	X	PW	NONE	1	8 oz	4 Lead by EPA 200.8		
5	FCE-015-F	X		4/2/2021	3:58AM	X	PW	NONE	1	8 oz	5 Lead by EPA 200.8		
6	FCE-017-F	X		4/2/2021	3:57AM	X	PW	NONE	1	8 oz	6 Lead by EPA 200.8		
7	FCE-019-F	X		4/2/2021	3:59AM	X	PW	NONE	1	8 oz	7 Lead by EPA 200.8		
8	FCE-022-F	X		4/2/2021	3:59AM	X	PW	NONE	1	8 oz	8 Lead by EPA 200.8		
9	FCE-025-BF	X		4/2/2021	3:57AM	X	PW	NONE	1	8 oz	9 Lead by EPA 200.8		
10	FCE-031-F	X		4/2/2021	4:00AM	X	PW	NONE	1	8 oz	10 Lead by EPA 200.8		
11	FCE-033-F	X		4/2/2021	4:00AM	X	PW	NONE	1	8 oz	11 Lead by EPA 200.8		
12	FCE-037-F	X		4/2/2021	4:10AM	X	PW	NONE	1	8 oz	12 Lead by EPA 200.8		
13	FCE-039-F	X		4/2/2021	4:10AM	X	PW	NONE	1	8 oz	13 Lead by EPA 200.8		
14	FCE-041-F	X		4/2/2021	4:09AM	X	PW	NONE	1	8 oz	14 Lead by EPA 200.8		

Client's Project I.D.: **Authorization / to #:** FN-06605

Notes and Hazard Identifications: **Please Fill Out Completely** **SAMPLES MUST BE RECEIVED ON ICE** **SAMPLES MUST BE RECEIVED ON ICE**

Notes and Hazard Identifications:
Results to: **Signature:** **Date:**
 jdrew@tstbooces.org *[Signature]* 4/6/21 2:00PM
 segan@tstbooces.org *[Signature]* 4/6/21 11:16
 malo@tstbooces.org *[Signature]* 4/6/21 16:30
 mmroi@tstbooces.org *[Signature]*

Shipment Method: **Received By:** **Received By:** **Received By:**
 Samples Received Intact: Y N *[Signature]* *[Signature]* *[Signature]*



Life Science Laboratories, Inc.
5854 Butternut Drive
East Syracuse, NY 13057

Phone # (315) 445-1900
Telefax # (315) 445-1104

Client: Ithaca City School District
Address: 400 Lake Street
Ithaca, NY 14850

Phone # (607) 280-3900
Fax #

2104722

IthacaCitySchools

2923

Chain of Custody Record

Contact Person: LSL Project #:
Paul Alexander
Client's Site I.D.:
ICSD - Fall Creek Elementary School - Lead

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers # size/type	Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.						
15 A	FCE-043-F	4/2/2021	4:07AM	X		PW	NONE	1 8 oz	FCE 15 Lead by EPA 200.8		✓
16	FCE-045-F	4/2/2021	4:09AM	X		PW	NONE	1 8 oz	16 Lead by EPA 200.8		
17	FCE-047-F	4/2/2021	4:08AM	X		PW	NONE	1 8 oz	17 Lead by EPA 200.8		
18	FCE-049-F	4/2/2021	4:06AM	X		PW	NONE	1 8 oz	18 Lead by EPA 200.8		
19	FCE-061-BF	4/2/2021	4:03AM	X		PW	NONE	1 8 oz	19 Lead by EPA 200.8		
20	FCE-063-F	4/2/2021	4:03AM	X		PW	NONE	1 8 oz	20 Lead by EPA 200.8		✓

SAMPLES MUST BE RECEIVED ON ICE Please Fill Out Completely **SAMPLES MUST BE RECEIVED ON ICE**

Notes and Hazard Identifications:

Results to: jdrew@tstbooces.org
segan@tstbooces.org
malo@tstbooces.org
mmiroiu@tstbooces.org

Print Name: MARK J. ALO Signature: *[Signature]*

Received By: *[Signature]* 4/5/21 2:00 PM
Relinquished By: *[Signature]* 4/6/21 11:10
Relinquished By: *[Signature]* Received for Lab By: *[Signature]* 4/6/21 16:30

Shipment Method: Y N 23.1°C
Samples Received Intact: Y N