



Life Science Laboratories, Inc.

Paul Alexander
Ithaca City School District
602 Hancock St.
Ithaca, NY 14850 USA

Phone: (607) 274-2142

Laboratory Analysis Report Prepared For Ithaca City School District

Client Project ID:

ICSD-Administration Bldg. - Lead

LSL Project ID: **2106930**

Receive Date/Time: 05/11/21 16:24

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain data qualifiers and specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab
5854 Butternut Drive
East Syracuse, NY 13057
Tel. (315) 445-1900
Fax (315) 445-1104
NYS DOH ELAP #10248

LSL North Lab
131 St. Lawrence Avenue
Waddington, NY 13694
Tel. (315) 388-4476
Fax (315) 388-4061
NYS DOH ELAP #10900

LSL Finger Lakes Lab
16 N. Main St., PO Box 424
Wayland, NY 14572
Tel. (585) 213-4090
Fax (585) 213-4192
NYS DOH ELAP #11667

LSL Southern Tier Office
Cuba, NY
Tel. (585) 209-4032

LSL MidLakes Office
Canandaigua, NY
Tel. (585) 728-3320

Reviewed by:


Kristin E. Carpenter, Quality Staff

Date:

05/24/21

-- LABORATORY ANALYSIS REPORT --

Ithaca City School District Ithaca, NY

Sample ID: ADM-003-F LSL Sample ID: 2106930-001

Location:

Sampled: 05/08/21 4:51 Sampled By: MA

Sample Matrix: PWS

Analytical Method	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
Analyte	Result	Units		
(1) EPA 200.8, Rev. 5.4 Metals	EPA 200.2			
Please refer to the next page				MT



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse, NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Administration Bldg. - Lead
Matrix: PWS

Client Sample ID: ADM-003-F

Lab ID: 2106930-001A
Collection Date: 05/08/21 4:51
Date Received: 05/11/21 16:24

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0037	mg/L	05/19/21 17:02

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

-- LABORATORY ANALYSIS REPORT --

Ithaca City School District Ithaca, NY

Sample ID: ADM-011-F LSL Sample ID: 2106930-002

Location:

Sampled: 05/08/21 4:51 Sampled By: MA

Sample Matrix: PWS

Analytical Method	Result	Units	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
(1) EPA 200.8, Rev. 5.4 Metals			EPA 200.2			MT
Please refer to the next page						



Life Science Laboratories, Inc.
 5854 Butternut Drive
 East Syracuse , NY 13057 (315) 445-1900

Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS
Project: Ithaca City School District
Location: ICSD-Administration Bldg. - Lead
Matrix: PWS

Client Sample ID: ADM-011-F

Lab ID: 2106930-002A
Collection Date: 05/08/21 4:51
Date Received: 05/11/21 16:24

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8,Rev.5.4	(EPA 200.2)
Lead	0.0015	mg/L	05/19/21 17:05

- Qualifiers:**
- * Value may exceed the Acceptable Level
 - E Value exceeds the instrument calibration range
 - J Analyte detected below the PQL
 - P Prim./Conf. column %D or RPD exceeds limit
 - B Analyte detected in the associated Method Blank
 - H Holding times for preparation or analysis exceeded
 - ND Not Detected at the Practical Quantitation Limit (PQL)
 - S Spike Recovery outside accepted recovery limits

