



First Draw: 1,540 ppb  
Flush: 16.2 ppb

First Draw: 705 ppb  
Flush: 103 ppb

First Draw: 15.6 ppb  
Flush: No Result  
(laboratory handling error)

- KEY:
- COLD WATER PIPING (BELOW)
  - COLD WATER LINE (ABOVE)
  - ARCHITECTURAL WALLS
  - ⊙ BUBBLERS W/O CENTRAL CHILLER
  - ⊖ WATER COOLER
  - ⊕ WATER FAUCETS (TAPS)

**LABELLA**  
Associates, D.P.C.

300 STATE STREET  
ROCHESTER, NY 14614  
P: (585) 454-6110  
F: (585) 454-3066  
www.labellapc.com

Engineering  
Architecture  
Environmental  
Planning

COPYRIGHT © 2014 LABELLA ASSOCIATES, D.P.C.

It is a violation of New York Education Law Article 149 Sec. 7209, for any person, unless acting under the direction of a licensed architect, professional engineer, or land surveyor, to alter in any way, if an item bearing the seal of an architect, engineer, or land surveyor is altered, the altering architect, engineer, or land surveyor shall affix to the item their seal and notation "altered" followed by their signature and date of such alteration, and a specific description of the alteration.

DRAWING NAME: BELLE SHERMAN (ANNEX) ELEMENTARY  
FIRST FLOOR LAYOUT

PROJECT NAME: ITHACA CITY SCHOOL DISTRICT  
WATER PROJECT MANAGEMENT SERVICES

REVISIONS:		
DRAWN BY:	DATE:	PROJECT NO.:
EMU	09/19/2016	2160845
ISSUED FOR:	SHEET NO.	