

**Lead Levels in First-Draw Drinking Water Samples
at Beverly J. Martin Elementary School
Ithaca City School District**

2005 Test Results

Location of Sample / Sample Description	Lead Level* [parts per billion (ppb), or micrograms per liter (µg/L)]
Hall 106 Water Cooler	6.75
Room 132 (Medical Office) Cold Water Faucet	22.50
Hall 145 Water Cooler (E)	32.40
Hall 145 Water Cooler (W)	8.64
Room 181 (Kitchen) Cold Water Faucet	49.20
Room 183 (Cafeteria) Water Cooler	28.30
Hall 221 Water Cooler	21.50
Room 223 (Staff Lounge) Cold Water Faucet	37.20
Hall 226 Water Cooler (E)	7.44
Hall 226 Water Cooler (W)	5.36
Hall 240 Water Cooler	12.40
Hall 320 Water Cooler	68.40
Hall 332 Water Cooler (E)	8.05
Hall 332 Water Cooler (W)	4.96

*The EPA action level for lead in school drinking water is 20 ppb, or 20 µg/L.

Note: All samples were collected the morning of August 5, 2005.