

**Lead Levels in First-Draw Drinking Water Samples  
at Caroline Elementary School  
Ithaca City School District**

*2005 Test Results*

<b>Location of Sample / Sample Description</b>	<b>Lead Level*</b> [parts per billion (ppb), or micrograms per liter (µg/L)]
Room 8 Drinking Fountain	18.30
Room 12 Drinking Fountain	23.10
Room 13 Drinking Fountain	27.90
Room 17 Drinking Fountain	19.70
Room 19 Drinking Fountain	10.90
Room 24 Drinking Fountain	10.20
Room 27 Drinking Fountain	9.36
Room 33 Drinking Fountain	13.30
Room 38 Drinking Fountain	11.50
Room 42 Drinking Fountain	9.38
Room 47 Drinking Fountain	8.58
Room 49 Drinking Fountain	44.40
Room 53 Drinking Fountain	16.10
Hall 61 Short Water Cooler	5.92
Hall 61 Tall Water Cooler	4.16
Room 64 (Staff Lounge) Cold Water Faucet	5.45
Room 70 (Medical Office) Cold Water Faucet	89.90
Room 83 (Kitchen) Cold Water Faucet - Double Sink	22.60
Room 83 (Kitchen) Cold Water Faucet - Center Sink	43.90
Hall A1 Drinking Fountain	3.22
Room A6 Drinking Fountain	17.10

Room A8 Drinking Fountain	6.94
Room A10 Drinking Fountain	1.51
Room A16 Drinking Fountain	2.93
Room A19 Drinking Fountain	3.20
Room A25 Drinking Fountain	1.82
Room A28 Drinking Fountain	6.82
Room A30 Drinking Fountain	8.37
Room A34 Drinking Fountain	16.80
Room A36 Drinking Fountain	17.90
Room A38 Drinking Fountain	8.78
Room A41 Drinking Fountain	2.57
Room A46 Drinking Fountain	1.82
Room A53 Drinking Fountain	14.20
Room A55 Drinking Fountain	9.47

\*The EPA action level for lead in school drinking water is 20 ppb, or 20 µg/L.

Note: All samples were collected the morning of August 31, 2005.