

**Lead Levels in First-Draw Drinking Water Samples  
at Cayuga Heights Elementary School  
Ithaca City School District**

*2005 Test Results*

Location of Sample / Sample Description	Lead Level* [parts per billion (ppb), or micrograms per liter (µg/L)]
Room 108 Water Cooler	1.67
Room 116 Drinking Fountain	16.00
Room 215 Drinking Fountain	7.98
Room 218 Drinking Fountain	10.80
Room 224 Drinking Fountain	7.36
Hall 245 Drinking Fountain	ND**
Hall 245 Water Cooler	ND
Hall 250 Drinking Fountain	ND
Hall 250 Water Cooler	ND
Room 256 (Kitchen) Cold Water Faucet (E)	7.62
Room 256 (Kitchen) Cold Water Faucet (W)	7.04
Room 258 Cold Water Faucet (used by After-School Program)	ND
Room A5 (Medical Office) Cold Water Faucet	23.30
Room A8 (Main Office) Cold Water Faucet	12.00
Room A14 Drinking Fountain	21.80
Hall A18 Drinking Fountain	ND
Hall A18 Water Cooler	3.56

\*The EPA action level for lead in school drinking water is 20 ppb, or 20 µg/L.

\*\*ND - None detected.

Note: All samples were collected the morning of August 26, 2005.