



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J9B1115

Ithaca City School District

Project Name: Added Drinking Fountains

Paul Alexander
602 Hancock Street
Ithaca, NY 14850

Project / PO Number: FN19-00740
Received: 02/22/2019 10:25
Reported: 03/06/2019 11:04

Analytical Testing Parameters

Client Sample ID: N.E. D.F. By Gym S1
Lab Sample ID: J9B1115-01
Sample Type: Grab

Collected By: DM-Client
Collection Date: 02/22/19
Collection Time: 06:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8, Rv. 5.4							
Lead	<0.0010	0.0150	0.0010	mg/L		02/28/19 0955	02/28/19 1301

Analytical Testing Parameters

Client Sample ID: N.E. D.F. By Gym S2
Lab Sample ID: J9B1115-02
Sample Type: Grab

Collected By: DM-Client
Collection Date: 02/22/19
Collection Time: 06:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8, Rv. 5.4							
Lead	<0.0010	0.0150	0.0010	mg/L		02/28/19 0955	02/28/19 1307

Analytical Testing Parameters

Client Sample ID: CHES DF By 234 S1
Lab Sample ID: J9B1115-03
Sample Type: Grab

Collected By: DM-Client
Collection Date: 02/22/19
Collection Time: 07:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals, Total - ICP/MS	Result	AL	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8, Rv. 5.4							
Lead	<0.0010	0.0150	0.0010	mg/L		02/28/19 0955	02/28/19 1308



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J9B1115

Analytical Testing Parameters

Client Sample ID: CHES DF By 234 S2
Lab Sample ID: J9B1115-04
Sample Type: Grab

Collected By: DM-Client
Collection Date: 02/22/19
Collection Time: 07:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 8 columns: Metals, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.0150, 0.0010, mg/L, 02/28/19 0955, 02/28/19 1312.

Analytical Testing Parameters

Client Sample ID: CHES DF By 116 S1
Lab Sample ID: J9B1115-05
Sample Type: Grab

Collected By: DM-Client
Collection Date: 02/22/19
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 8 columns: Metals, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.0150, 0.0010, mg/L, 02/28/19 0955, 02/28/19 1314.

Analytical Testing Parameters

Client Sample ID: CHES DF By 116 S2
Lab Sample ID: J9B1115-06
Sample Type: Grab

Collected By: DM-Client
Collection Date: 02/22/19
Collection Time: 07:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 8 columns: Metals, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.0150, 0.0010, mg/L, 02/28/19 0955, 02/28/19 1316.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J9B1115

Analytical Testing Parameters

Client Sample ID: FC DF By A112 S1
Lab Sample ID: J9B1115-07
Sample Type: Grab

Collected By: DM-Client
Collection Date: 02/22/19
Collection Time: 08:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 8 columns: Metals, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.0150, 0.0010, mg/L, 02/28/19 0955, 02/28/19 1321

Analytical Testing Parameters

Client Sample ID: FC DF By A112 S2
Lab Sample ID: J9B1115-08
Sample Type: Grab

Collected By: DM-Client
Collection Date: 02/22/19
Collection Time: 08:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 8 columns: Metals, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.0150, 0.0010, mg/L, 02/28/19 0955, 02/28/19 1323

Analytical Testing Parameters

Client Sample ID: BJM DF Cafe S1
Lab Sample ID: J9B1115-09
Sample Type: Grab

Collected By: DM-Client
Collection Date: 02/22/19
Collection Time: 08:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 8 columns: Metals, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.0150, 0.0010, mg/L, 02/28/19 0955, 02/28/19 1325



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J9B1115

Analytical Testing Parameters

Client Sample ID: BJM DF Cafe S2
Lab Sample ID: J9B1115-10
Sample Type: Grab

Collected By: DM-Client
Collection Date: 02/22/19
Collection Time: 08:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 8 columns: Metals, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.0150, 0.0010, mg/L, 02/28/19 0955, 02/28/19 1327

Analytical Testing Parameters

Client Sample ID: ENF DF By Cafe S1
Lab Sample ID: J9B1115-11
Sample Type: Grab

Collected By: DM-Client
Collection Date: 02/22/19
Collection Time: 08:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 8 columns: Metals, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.0150, 0.0010, mg/L, 02/28/19 0955, 02/28/19 1329

Analytical Testing Parameters

Client Sample ID: ENF DF By Cafe S2
Lab Sample ID: J9B1115-12
Sample Type: Grab

Collected By: DM-Client
Collection Date: 02/22/19
Collection Time: 08:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 8 columns: Metals, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.0150, 0.0010, mg/L, 02/28/19 0955, 02/28/19 1332

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: US EPA Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 10.8°C



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J9B1115

Cooler Inspection Checklist

Table with 4 columns: Question, Yes, No, and Answer. Rows include items like 'Ice Present or not required?', 'Shipping containers sealed or not required?', etc.

Project Requested Certification(s)

11549
Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health
New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Handwritten signature of Shannon Weeks

Shannon Weeks
Customer Relationship Coordinator
03/06/2019 11:04

Go Green: Contact Shannon Weeks to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Client Information			Billing/Invoice:			Analysis Requested			Receiving Info (Lab Use Only)		
Name: ITHACA CITY SCHOOLS									Ice: YES NO		
Address: 602 Hancock St.									Cooler: YES NO		
ITHACA NY 14850									Sample Temp: 10.8		
Contact: Carl Slack									Cooler Seal: YES NO		
Phone: (607) 423-3597									Pickup: YES NO		
Project: ADDED DRINKING FOUNTAINS									Dropoff: C W		
Quote ID: PO# FM19-00740									Accepted? YES NO		
Rush TAT Bus. Days: <2 2-5 5-7 7-10									Container Material		
Release to DOH: Yes									Container Size(in MI)		
Email Results: Paalexand@icsd.k12.ny.us									Preservative		
Fax Results: Yes									Comments/Field Data		
Sample Information				Matrix		Number of Containers for Analysis Requested		Comments			
Description/Location	Date	Time	Initial	Type							
1 N.E. D.F. BY GYM S1	2/22/19	6:58	D.M	DW	1						
2 N.E. D.F. BY GYM S2		6:58	D.M								
3 Ches. Df BY 234 S1		7:16	D.M								
4 Ches. Df BY 234 S2		7:17	P.M								
5 Ches. Df BY 116 S1		7:31	D.M								
6 Ches. Df BY 116 S2		7:32	D.M								
7 F.C. Df BY A112 S1		8:07	D.M								
8 F.C. Df BY A112 S2		8:07	D.M								
Print Name and Company				Signature		Date/Time		Comments			
DAN MATHIEWS				Dan Mathews		2-22-19 / 10:25					
Chamber Schmidt				Chamber Schmidt		2/22/19 10:25					
Received:											
Received:											
Received:											
Received:											
Received:											



Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice

2 of 2

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name: ITHACA CITY SCHOOLS						Ice: YES NO	
Address: 602 HAYCOCK ST.						Cooler: YES NO	
ITHACA NY 14850						Sample Temp: 10.8	
Contact: Carl Slack						Cooler Seal: YES NO	
Phone: (607) 423-3597						Pickup: YES NO	
Project:						Dropoff: C W	
Quote ID:						Accepted? YES NO	
Rush TAT Bus. Days: <2 2-5 5-7 7-10						Container Material	
Release to DOH: Yes						Container Size (in Mil)	
Email Results: Yes		Pa.alexand@icsd.k12.ny.us				Preservative	
Fax Results: Yes						Comments/Field Data	
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix Type			
1 BSM Df Cafe S1	2/22/19	8:18	D.M	DW			
2 BSM Df Cafe S2		8:19	D.M				
3 Env Df BYCafe S1		8:49	D.M				
4 Env Df BYCafe S2		8:49	D.M				
5							
6							
7							
8							
Print Name and Company				Signature		Date/Time	
Sampled: DNN MATHCROSS				DNN MATHCROSS		2/22/19 10:25	
Received: Amber Schmitt				Amber Schmitt		2/22/19 10:05	
Received:							
Received:							
Received:							



Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.