

**Lead Levels in First-Draw Drinking Water Samples
at Lehman Alternative Community School
Ithaca City School District**

2005 Test Results

Location of Sample / Sample Description	Lead Level* [parts per billion (ppb), or micrograms per liter ($\mu\text{g/L}$)]
Hall 114 Water Cooler	9.57
Hall 202 Drinking Fountain	9.65
Hall 202 Water Cooler	14.00
Room 204 (Main Office) Cold Water Faucet	10.20
Room 205 (Medical Office) Cold Water Faucet	17.40
Room 247 (Kitchen) Cold Water Faucet	30.70

*The EPA action level for lead in school drinking water is 20 ppb, or 20 $\mu\text{g/L}$.

Note: All samples were collected the morning of August 11, 2005.