

**CAROLINE SCHOOL NEW DRINKING FOUNTAINS/BOTTLE FILLER LEAD TESTING
8.14.2018**

Client Sample ID: Car. D.F. By Rm 69 S1	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/14/2018 5:15
Lab Sample ID: J8H1357-99	

Lead and/or Copper, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8/EPA 200.8, Rv 5.4								
Lead	<0.000500	0.0150 AL	0.000500	mg/L		08/20/18 1131	08/20/18 1806	JAH

Client Sample ID: Car. D.F. By Rm 69 S2	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/14/2018 5:15
Lab Sample ID: J8H1357-AA	

Lead and/or Copper, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8/EPA 200.8, Rv 5.4								
Lead	<0.000500	0.0150 AL	0.000500	mg/L		08/20/18 1131	08/20/18 1809	JAH

Client Sample ID: Car. D.F. By Boiler Rom S1	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/14/2018 6:12
Lab Sample ID: J8H1357-AB	

Lead and/or Copper, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8/EPA 200.8, Rv 5.4								
Lead	<0.000500	0.0150 AL	0.000500	mg/L		08/20/18 1341	08/20/18 1849	JAH

Client Sample ID: Car. D.F. By Boiler Rom S2	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 08/14/2018 6:12
Lab Sample ID: J8H1357-AC	

Lead and/or Copper, Total - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8/EPA 200.8, Rv 5.4								
Lead	<0.000500	0.0150 AL	0.000500	mg/L		08/20/18 1407	08/21/18 1944	JAH