

**Lead Levels in First-Draw Drinking Water Samples
at Northeast Elementary School
Ithaca City School District**

2005 Test Results

Location of Sample / Sample Description	Lead Level* [parts per billion (ppb), or micrograms per liter (µg/L)]
Room 8 (Kitchen) Cold Water Faucet (E)	3.11
Room 8 (Kitchen) Cold Water Faucet (W)	7.10
Hall 16 Short Water Cooler	2.04
Hall 16 Tall Water Cooler	2.44
Room 30 (Medical Office) Cold Water Faucet	45.40
Room 31 (Main Office) Cold Water Faucet	24.00
Hall 26 Water Cooler	56.90
Hall 101 Drinking Fountain	3.68
Hall 101 Water Cooler	6.43
Room 104 Drinking Fountain	12.60
Room 107 Drinking Fountain	10.70
Room 111 Drinking Fountain	14.70
Room 114 Drinking Fountain	17.40
Room 117 Drinking Fountain	15.70
Room 120 Drinking Fountain	24.60
Room 123 Drinking Fountain	16.40
Room 126 Drinking Fountain	18.60
Room 131 Drinking Fountain	11.60
Room 137 Drinking Fountain	12.10
Hall 201 Water Cooler	2.03
Room 204 Drinking Fountain	11.50

Room 207 Drinking Fountain	10.30
Room 211 Drinking Fountain	31.60
Room 214 Drinking Fountain	15.10
Room 217 Drinking Fountain	9.60
Room 220 Drinking Fountain	11.20
Room 223 Drinking Fountain	8.82
Room 226 Drinking Fountain	13.30
Room 231 Cold Water Faucet	3.51
Room 233 Drinking Fountain	11.60
Room A2 (Library) Water Cooler	28.20
Room A3 Drinking Fountain	6.94
Room A7 Drinking Fountain	9.77
Room A8 Drinking Fountain	21.40
Room A12 Drinking Fountain	12.20
Room A14 Drinking Fountain	5.73
Room A18 Drinking Fountain	3.18
Room A20 Drinking Fountain	10.70
Room A21 Drinking Fountain	18.70
Room A25 Drinking Fountain	31.30
Room A26 Drinking Fountain	25.50

*The EPA action level for lead in school drinking water is 20 ppb, or 20 µg/L.

Note: All samples were collected the morning of August 30, 2005.