

PPB Caroline School Sample Sites								
Site	Description	Sample Time	Sampler	Notes		Lead PPB	Copper Results (mg/L)	
1	Main Office	5:30:00 AM	JW	Sink		11.0000	0.100	
2	Room 60	4:57:00 AM	DW	Boiler Room Sink		7.4000	0.079	
3	Drinking Fountain	4:58:00 AM	CK	In hallway closer to boiler room		1.0000	0.110	
4	Drinking Fountain	4:57:00 AM	DW	In hallway closer to boys room		1.0000	0.098	
5	Room 58	5:03:00 AM	CK	Boy's Bathroom Porcelain Sink		5.3000	0.320	
6	Room 58	5:04:00 AM	CK	Boys Bathroom Metal Sink		39.0000	0.890	
7	Room 57	5:05:00 AM	CK	Custodial Closet Mop Sink		33.0000	1.200	
8	Room 56	5:06:00 AM	CK	Girls Bathroom Metal Sink		46.0000	0.410	
9	Room 56	5:07:00 AM	CK	Birls Bathroom Porcelain Sink		53.0000	0.380	
10	Ward	5:08:00 AM	CK	Classroom Drinking Fountain		150.0000	0.190	
11	Ward	5:09:00 AM	CK	Classroom Sink		120.0000	0.340	
12	Devoe/Hastings/McCleary	5:10:00 AM	CK	Classroom Drinking Fountain		120.0000	0.700	
13	Devoe/Hastings/McCleary	5:11:00 AM	CK	Classroom Sink		75.0000	1.400	
14	Beeners	5:11:00 AM	CK	Classroom Drinking Fountain		7.0000	0.170	
15	Beeners	5:13:00 AM	CK	Classroom Sink		14.0000	0.290	
16	Beeners/Crossgrove	5:13:00 AM	CK	Bathroom Sink		24.0000	2.700	
17	Crossgrove	5:14:00 AM	CK	Classroom Drinking Fountain		7.8000	0.740	
18	Crossgrove	5:15:00 AM	CK	Classroom Sink		31.0000	1.900	
19	Ink	5:17:00 AM	CK	Classroom Drinking Fountain	RUSH	49.0000	0.840	
20	Ink	5:20:00 AM	CK	Classroom Sink		550.0000	8.800	
21	Ink	5:21:00 AM	CK	Bathroom Sink		12.0000	0.140	
22	Keating	5:21:00 AM	DW	Classroom Drinking Fountain		2.1000	0.061	
23	Keating	5:22:00 AM	DW	Classroom Sink		10.0000	0.350	
24	Keating	5:21:00 AM	JW	Bathroom Sink		56.0000	3.200	
25	Weber	5:16:00 AM	DW	Classroom Drinking Fountain	RUSH	84.0000	8.000	
26	Weber	5:19:00 AM	DW	Classroom Sink	RUSH	180.0000	4.000	
27	Weber	5:20:00 AM	DW	Bathroom Sink		44.5000	0.233	
28	Shululu	5:13:00 AM	DW	Classroom Drinking Fountain		37.0000	2.700	
29	Shululu	5:14:00 AM	DW	Classroom Sink		17.0000	1.000	
30	Shululu/Duell/Green	5:12:00 AM	DW	Bathroom Sink		3.1000	0.160	
31	Duell/Green	5:10:00 AM	DW	Classroom Drinking Fountain		5.5000	0.120	
32	Duell/Green	5:11:00 AM	DW	Classroom Sink		15.0000	0.084	
33	Grainger	5:08:00 AM	DW	Classroom Drinking Fountain		3.4000	0.067	
34	Grainger	5:07:00 AM	DW	Classroom Sink		13.0000	0.210	
35	Room 13	5:06:00 AM	DW	Classroom Drinking Fountain		8.7000	0.840	
36	Room 13	5:07:00 AM	DW	Classroom Sink		49.0000	0.062	
37	Stephenson/Johnson	5:03:00 AM	DW	Classroom Drinking Fountain		22.0000	1.400	
38	Stephenson/Johnson	5:05:00 AM	DW	Classroom Sink		18.0000	0.950	
39	Room 8	5:01:00 AM	DW	Library Drinking Fountain		3.2000	0.620	
40	Room 8	5:02:00 AM	DW	Library Sink		15.0000	0.130	
41	Room 83	5:28:00 AM	DW	Kitchen Sink in Center of Room		5.0000	0.070	
42	Room 83	5:29:00 AM	DW	Kitchen Sink Near Door		2.2000	0.100	

43	Room 64	5:30:00 AM	DW	Faculty Lounge Kitchen Sink	16.0000	0.530
44	Room 65	5:32:00 AM	CK	Staff bathroom sink	2.8000	0.210
45	Room 69	5:33:00 AM	DW	Staff bathroom sink	8.2000	0.150
46	Room 70	5:33:00 AM	DW	Nurses room sink	27.0000	0.540
47	Room 70	5:33:00 AM	CK	nurses bathroom sink	52.0000	3.200
48	Room A2	5:34:00 AM	DW	Girls bathroom sink- closer to door	17.0000	0.820
49	Room A2	5:35:00 AM	DW	girls bathroom sink- in corner	16.0000	0.750
50	Drinking Fountain	5:34:00 AM	CK	In hallway between rooms A2 and A3	100.0000	2.300
51	Room A3	5:35:00 AM	DW	Custodial closet mop sink	17.0000	0.320
52	Room A4	5:35:00 AM	DW	boys bathroom- closer to door	2.4000	0.160
53	Room A4	5:36:00 AM	CK	Boys bathroom- in corner	4.8000	0.260
54	Room A5	5:37:00 AM	DW	Staff bathroom sink	22.0000	1.300
55	Chamberlain/Flavin/Ford	5:38:00 AM	CK	Classroom Drinking Fountain	12.0000	0.091
56	Chamberlain/Flavin/Ford	5:40:00 AM	CK	Classroom Sink	29.0000	0.099
57	Conklin	5:39:00 AM	DW	Classroom Drinking Fountain	1.9000	0.074
58	Conklin	5:40:00 AM	DW	Classroom Sink	6.2000	0.078
59	Chapman	5:41:00 AM	DW	Classroom Drinking Fountain	12.0000	1.100
60	Chapman	5:44:00 AM	DW	Classroom Sink	370.0000	19.000
61	Beigel	5:46:00 AM	DW	Classroom Drinking Fountain	62.0000	7.800
62	Beigel	5:48:00 AM	DW	Classroom Sink	1000.0000	5.100
63	Room A10/A16	5:47:00 AM	JW	Bathroom Sink	4.1000	0.350
64	Rottenstein	5:49:00 AM	CK	Classroom Drinking Fountain	7.2000	0.790
65	Rottenstein	5:51:00 AM	DW	Classroom Sink	390.0000	7.000
66	Rottenstein/VanGorder	5:45:00 AM	JW	bathroom Sink	3.1000	0.300
67	VanGorder	5:45:00 AM	CK	Classroom Drinking Fountain	53.0000	2.800
68	VanGorder	5:45:00 AM	CK	Classroom Sink	710.0000	10.000
69	Cecere	5:42:00 AM	CK	Classroom Drinking Fountain	2.6000	0.082
70	Cecere	5:43:00 AM	CK	Classroom Sink	20.0000	0.210
71	Emerson	5:41:00 AM	CK	Classroom Dinking fountain	2.3000	0.062
72	Emerson	5:42:00 AM	CK	Classroom Sink	13.0000	0.100
73	Gondek/Hill	5:53:00 AM	DW	Classroom Drinking Fountain	51.0000	0.260
74	Gondek/Hill	5:54:00 AM	DW	classroom Sink	22.0000	0.350
75	Goodmark	5:54:00 AM	DW	classroom Drinking fountain	11.0000	0.110
76	Goodmark	5:54:00 AM	CK	Classroom Sink	21.0000	0.110
77	Wells	5:55:00 AM	JW	Dlassroom drinking fountain	5.2000	0.080
78	Wells	5:56:00 AM	CK	Classroom sink	24.0000	0.140
79	Cushman/Preston	6:01:00 AM	CK	Music Room Drinking Fountain	24.0000	2.400
80	Cushman/Preston	6:04:00 AM	CK	Music Room Sink	940.0000	15.000
81	Cushman/Preston	5:58:00 AM	JW	Music Bathroom Sink	5000.0000	46.000
82	Burke	6:01:00 AM	DW	Classroom Drinking Fountan	57.0000	2.100
83	Burke	6:05:00 AM	DW	Classrooms Sink	2200.0000	28.000
84	Burke	6:04:00 AM	JW	Metal Utility Sink	760.0000	11.000
85	Daly/Schlenker	5:57:00 AM	DW	Classroom Drinking Fountain	7.4000	0.096
86	Daly/Schlenker	5:58:00 AM	DW	Classroom Sink	11.0000	0.091
87	Carlson/Lovell/McCleary	5:56:00 AM	DW	Classroom Drinking Fountain	119.0000	0.174

88	Carlson/Lovell/McCleary	5:56:00 AM	DW	Classroom Slnk	9.0000	0.140
89	Room A49	6:07:00 AM	DW	Room A46 bathroom Sink	6.8000	0.370
90	Entry point	4:57:00 AM	DW	Boiler Room - Pre-chlorination	68.0000	1.100
91	Room 63	8:04:00 AM	DW	Faculty Lounge Water Cooler	1.0000	<0.001