

PPB Enfield School Sample Sites

Site	Description	Sample Time	Sample	Notes	Lead PPB	Copper Results (mg/L)
1	Main Office	6:51:00 AM	CK	Office sink	4.0000	0.180
2	Drinking Fountain	6:52:00 AM	JW	Right Side in Lobby	1.0000	0.100
3	Drinking Fountain	6:52:00 AM	DW	Left Side in Lobby	1.0000	0.190
4	Room B17	6:54:00 AM	DW	Custodial Closet Mop Sink	3.5000	0.100
5	Thannhauser/Naylor	6:55:00 AM	JW	Classroom Drinking Fountain	2.5000	0.140
6	Thannhauser/Naylor	6:57:00 AM	CK	Classroom Sink	8.4000	0.120
7	Thannhauser/Naylor	6:55:00 AM	DW	Bathroom Sink	1.8000	0.110
8	Larkin	1:40:48 PM	DW	Classroom Drinking Fountain	1.3000	0.099
9	Larkin	1:55:12 PM	DW	Classroom Sink	2.8000	0.089
10	Larkin/Rekczis	2:09:36 PM	DW	Bathroom Sink	1.5000	0.140
11	Rekczis	2:09:36 PM	DW	Classroom Drinking Fountain RUSH	1.9000	0.110
12	Rekczis	12:28:48 AM	DW	Classroom Sink	2.7000	0.100
13	Cudlin	12:14:24 AM	CK	Classroom Drinking Fountain	1.5000	0.100
14	Cudlin	12:14:24 AM	CK	Classroom Sink	4.9000	0.097
15	Cudlin/Pallor	2:09:36 PM	JW	Bathroom Sink	1.6000	0.100
16	Pallor	1:55:12 PM	CK	Classroom Drinking Fountain	2.2000	0.130
17	Pallor	12:00:00 PM	DW	Classroom Sink	7.7000	0.120
18	Keefner	12:57:36 PM	CK	Classroom Drinking Fountain	2.9000	0.150
19	Keefner	12:43:12 PM	CK	Classroom Sink	49.0000	0.840
20	Room 28	12:43:12 AM	DW	Boys bathroom- shorter sink, closer to door Hot Water	4.3000	0.140
21	Room 28	12:57:36 AM	DW	Boys bathroom- taller sink, further from door	2.3000	0.230
22	Room 26	1:26:24 AM	CK	Mop Sink	2.9000	0.100
23	Drinking Fountain	12:57:36 AM	JW	Hallway between rooms 26 and 25	12.0000	0.120
24	Room 25	1:40:48 AM	JW	Girls bathroom- shorter sink closer to door RUSH	280/268	0.812/0.806
25	Room 25	1:40:48 AM	CK	Girls bathroom- taller sink further from door	3.3000	0.140
26	Niles/Blume/Benzer	2:09:36 AM	CK	Sink	2.6000	0.110
27	Room 18	2:24:00 AM	DW	Women's Room Sink	1.5000	0.083
28	Room 19	2:24:00 AM	JW	Men's Room Sink	2.1000	0.088
29	Haldeman	2:38:24 AM	DW	Classroom Drinking Fountain	3.3000	0.110
30	Haldeman	2:52:48 AM	DW	Classroom Sink	5.7000	0.120
31	Dresen	3:07:12 AM	DW	classroom drinking fountain	1.8000	0.110
32	Dresen	3:21:36 AM	DW	classroom sink	3.1000	0.120
33	Mazur	3:50:24 AM	DW	art room drinking fountain	7.9000	0.100
34	Mazur	4:04:48 AM	DW	art room sink	19.0000	0.100
35	Mazur	4:19:12 AM	DW	art room utility sink	6.3000	0.096
36	Brautigam	4:33:36 AM	DW	classroom drinking fountain	3.5000	0.110
37	Brautigam	4:48:00 AM	DW	classroom sink	7.6000	0.120
38	Mordock/Park/Harned/Abb	5:31:12 AM	DW	classroom drinking fountain	6.6000	0.110
39	Mordock/Park/Harned/Abb	5:45:36 AM	DW	classroom sink	6.6000	0.100
40	Goodman	5:02:24 AM	DW	classroom drinking fountain	4.2000	0.130
41	Goodman	5:16:48 AM	DW	classroom sink	8.0000	0.140
42	Steiner	5:16:48 AM	CK	classroom drinking fountain RUSH	37.9/281	0.415/0.861
43	Steiner	5:31:12 AM	CK	classroom sink	9.7000	0.190
44	Brooks	5:02:24 AM	JW	classroom drinking fountain	190.0000	0.140
45	Brooks	5:02:24 AM	JW	classroom sink	260.0000	0.170
46	Griffen	4:48:00 AM	CK	classroom drinking fountain	4.8000	0.120
47	Griffen	5:02:24 AM	CK	classroom sink	50.0000	0.590
48	Room A9	4:04:48 AM	CK	boys room- closer to door Hot Water	51.0000	0.220
49	Room A9	4:33:36 AM	DW	boys room- further from door	6.4000	0.180
50	Room A8	3:50:24 AM	DW	Custodial Closet Mop Sink	8.5000	0.140
51	Drinking Fountain	3:36:00 AM	CK	Hallway between room A7 and A8	3.0000	0.100
52	Room A7	3:50:24 AM	JW	girls bathroom- closer to door RUSH	4.9000	0.120
53	Room A7	4:04:48 AM	CK	girls bathroom- further from door	6.6000	0.160
54	Halton	2:52:48 AM	CK	classroom drinking fountain	1.8000	0.098
55	Halton	3:07:12 AM	CK	classroom sink	3.1000	0.160

*Pre Digestion Result/ Post Digestion Result

*Pre Digestion Result/ Post Digestion Result

56	Ciferri	2:38:24 AM	CK	classroom drinking fountain		2.9000	0.099						
57	Ciferri	2:52:48 AM	CK	classroom sink		1.0000	0.100						
58	Drinking Fountain	2:24:00 AM	DW	in hallway by room 2		82.0000	0.130						
59	Room 35	2:24:00 AM	CK	kitchen sink		1.3000	0.120						
60	Bakos	12:57:36 AM	CK	classroom drinking fountain		3.1000	0.110						
61	Bakos	1:12:00 AM	CK	Classroom sink		10.0000	0.110						
62	Boiler room	12:00:00 PM	DW	Tap		640.0000	2.800						
63	Graham/Condon/Lazarre/Gilroy	6:43:12 AM	CK	Drinking Fountain	NOT FLUSHED	10.0000	0.160						
64	Graham/Condon/Lazarre/Gilroy	6:43:12 AM	DW	Sink	NOT FLUSHED	15.0000	0.140						
65	Boiler room	12:00:00 PM	DW	Entry Point		48.0000	0.780						